


The diagram illustrates the electrical connection for a three-phase active energy meter. It shows the incoming supply lines (L1, L2, L3) and the PEN line. The meter is connected through a switch and a 25A fuse. The meter is labeled '3-fazowy licznik (kWh) energii czynnej (Energia Operator S.A.)'. The diagram also shows a kWh meter and a 25A fuse. The diagram is labeled 'Wzł. taryfowy' and 'Zwory'.

1. Ochrona przed dotykiem pośrednim – samoczynne wyłączenie zasilania w układzie sieci TN-C



	Skala:	–
	Data:	12.20